



## LEBANON FIRE DEPARTMENT

12 South Park Street  
Lebanon, NH 03766

Phone: 603-448-8810  
FAX: 603-448-8811  
Email: [fire@lebanonnh.gov](mailto:fire@lebanonnh.gov)

### Requirements for Commercial Outdoor Cooking:

#### Farmer's Market, Open Sided Pop-Up Style Tents, and Similar Situations:

- **All** cooking equipment that does not create grease laden vapors shall have a minimum of (1) 5 pound or 2A10BC minimum rated multi-purpose dry chemical extinguisher readily accessible to the operator.
- **All** cooking equipment that creates grease laden vapors (broilers, fryolaters, cooking of bacon, burgers, etc) shall have a minimum of (1) 6 liter Class K fire extinguisher.

#### Mobile Food Trucks:

- **All mobile food trucks shall be required to have an inspection and operational permit issued by the Lebanon Fire Department prior to operating within the City of Lebanon. Permits are issued by the Lebanon City Manager's Office. To schedule the inspection please contact Maddy Goodell at 603-448-8810 at the Lebanon Fire Department, Station 1.**
- **Any mobile food truck operating within the City of Lebanon that produces grease laden vapors shall be equipped with an automatic fire extinguishing system per the 2018 IFC Section 319.4.1.**
- **Any mobile food truck operating within the City of Lebanon that uses LP-gas shall be equipped with a listed LP-gas alarm per the 2018 IFC Section 319.8.5**
- **All mobile food trucks shall be required to have an inspection and operational permit issued by the Lebanon Fire Department prior to operating within the City of Lebanon.**
- **All** mobile food trucks that do not create grease laden vapors shall have at a minimum (1) 5 pound or 2A10BC minimum rated, multi-purpose fire extinguisher in the path of egress from the cooking area.
- **All** mobile food trucks that create grease laden vapors shall have the following equipment:
  - Exhaust system which includes grease removal devices (IFC 319.3)
  - (1) 6 liter Class K fire extinguisher in the path of egress (IFC 319.4.2)
- Mobile food trucks that utilize propane fueled cooking equipment shall comply with the following:
  - LP-gas containers transported on the vehicle and used to fuel cooking appliances shall not exceed 200 pounds propane capacity (IFC 319.8.1)
  - LP-gas containers shall be securely mounted and restrained to prevent movement (IFC 319.8.2)

Questions related to this bulletin should be directed to the Lebanon Fire Department, Fire Prevention Division at 603-448-8810. To review all of the applicable requirements for mobile food preparation vehicles, please visit the International Code Council website, 2018 International Fire Code, Section 319. The link is provided below.

<https://codes.iccsafe.org/public/document/IFC2018/CHAPTER-3-GENERAL-REQUIREMENTS>

*Issued: January 29, 2019*